

# LAPORAN PEKERJAAN

Periode September s/d Desember 2023

APLIKASI SMART OPERATION PLTU BENGKAYANG

Oleh:

Prof. Ir. Yazid Bindar, PhD dan Tim LAPI ITB



# SMART OPERATION

PROPERTY OF  
 PT PLN Unit Pembangkit Kalimantan  


DEVELOPED BY  
 PT LAPITO (@Yazid Bindar and Team)

Ready



EMMISSION



OPERATION FORECASTING



INPUT DATA

ADB		DAFB		ARB	
C	51.6 %	N	1.03 %	MC	41.48 %
H	3.87 %	TOTAL SULPHUR	0.37 %	ASH	8.65 %
O	13.53 %	TOTAL SULPHUR	0.19 %		
ASH	12.14 %				

CONVERT

RESET

ARB

C	36.77 %	O	9.64 %	S	0.19 %
H	2.76 %	N	0.51 %	MC	41.48 %

Insert To

COAL ID I

COAL ID II

COAL ID III

OPERATING CONDITION


O2 Content in FG

O2 Content  %

PA and SA

SAMPLE IDENTIFICATION		COAL FEEDER UNIT #1 / 35 MW				
DATE OF REPORT		7-Dec-22				
NO	PARAMETERS	UNITS	AR	ADB	DB	DAF
1	Total Moisture	%	41.48	-	-	-
<b>PROXIMATE</b>						
2	Moisture in Analysis	%	-	17.88	-	-
3	Ash Content	%	8.65	12.14	14.78	-
4	Volatile Matter	%	27.75	38.94	47.42	55.64
5	Fixed Carbon	%	22.12	31.04	37.8	44.36
6	Total Sulphur	%	0.19	0.26	0.32	0.37
7	Carbon	%	36.77	51.6	62.83	73.74
8	Hydrogen	%	2.76	3.87	4.71	5.53
9	Nitrogen	%	0.51	0.72	0.88	1.03
10	Oxygen	%	9.64	13.53	16.48	19.33
11	CGV	Kcal/Kg	3366	4723	5751	6749

BUSTION SYSTEM  
KAYANG 2X50 MW



Furnace In Temp  degC

High Temp Superheater  degC

Low Temp Superheater  degC

Economizer  degC

PERFORMANCE

NPHR  Kcal/kWh

Thermal Efficiency  -%

Boiler Efficiency  -%

FLUE GAS

Volumetric Flow (db)

Nm3/h

SO2

%-db

mg/Nm3

CO2

%-db

Nm3/h

NO2

%-db

mg/Nm3

Description




EMISSION



OPERATION FORECASTING

# DATA OPERASI

Time	TIME	7/12/2022 19:00
AMMW_TODCS.AV	UNIT POWER (GENERATOR)	40.73
MCS12MCS01A02.AV	COAL FEED	31.09
10HLA10CF101_BC.AV	PAF(A) OUTLET AIR FLOW	35054.73
10HLA20CF101_BC.AV	PAF(B) OUTLET AIR FLOW	29672.67
10HLA60CF101_BC.AV	SAF(A) OUTLET AIR FLOW	37377.76
10HLA70CF101_BC.AV	SAF(B) OUTLET AIR FLOW	51454.32
10HBK10CT021.AV	FURNACE OUTLET TEMP.(LEFT)	865.91
10HBK10CT022.AV	FURNACE OUTLET TEMP.(RIGHT)	880.55
10HBK10CT017.AV	FURNACE BOTTOM TEMP.A(LEFT)	817.39
10HBK10CT019.AV	FURNACE BOTTOM TEMP.A(RIGHT)	848.53
10HBK10CT018.AV	FURNACE BOTTOM TEMP.B(LEFT)	804.38
10HBK10CT020.AV	FURNACE BOTTOM TEMP.B(RIGHT)	842.52
10HBK10CT013.AV	BED UPPER PART TEMP.A(LEFT)	804.59
10HBK10CT015.AV	BED UPPER PART TEMP.A(RIGHT)	816.89
10HBK10CT014.AV	BED UPPER PART TEMP.B(LEFT)	817.13
10HBK10CT016.AV	BED UPPER PART TEMP.B(RIGHT)	828.49
10HBK10CT009.AV	BED MIDDLE PART TEMP.A(LEFT)	801.94
10HBK10CT011.AV	BED MIDDLE PART TEMP.A(RIGHT)	836.82
10HBK10CT010.AV	BED MIDDLE PART TEMP.B(LEFT)	892.44
10HBK10CT012.AV	BED MIDDLE PART TEMP.B(RIGHT)	884.67
10HBK10CT005.AV	BED LOWER PART TEMP.C(FRONT)	885.98
10HBK10CT008.AV	BED LOWER PART TEMP.C(REAR)	909.01
10HBK10CT004.AV	BED LOWER PART TEMP.B(FRONT)	865.55
10HBK10CT007.AV	BED LOWER PART TEMP.B(REAR)	949.82
10HBK10CT003.AV	BED LOWER PART TEMP.A(FRONT)	877.88
10HBK10CT006.AV	BED LOWER PART TEMP.A(REAR)	915.05
10HBK10CT001.AV	AIR CHAMBER TEMP.A(FRONT)	179.34



COAL BLENDING TYPE

Single  Double  Triple

COAL ID-I	COAL ID-II	COAL ID-III	COAL BLEND
Coal Feed	Coal Feed	Coal Feed	Coal Feed
31.09 T/h	T/h	T/h	T/h
Composition	Composition	Composition	Composition
100 -%	-%	-%	-%
Ult-Analysis	Ult-Analysis	Ult-Analysis	Ult-Analysis
c 36.77 %-arb	c %-arb	c %-arb	c %-arb
H 2.76 %-arb	H %-arb	H %-arb	H %-arb
O 9.64 %-arb	O %-arb	O %-arb	O %-arb
N 0.51 %-arb	N %-arb	N %-arb	N %-arb
S 0.19 %-arb	S %-arb	S %-arb	S %-arb
MC 41.48 %-arb	MC %-arb	MC %-arb	MC %-arb
ASH 8.65 %-arb	ASH %-arb	ASH %-arb	ASH %-arb

GCV 3435.73 kcal/kg

CALCULATE


RESET

OPERATING CONDITION

<input type="radio"/> O2 Content in FG	O2 Content	7.89 %
<input checked="" type="radio"/> PA and SA	Primary Air	64727.4 Nm3/h
	Secondary Air	88832.08 Nm3/h
	Air Temp	179.34 degC
	Steam Flow	125 T/h
	Nett Generator Output	40.73 MWh
<b>AIR</b>		
	Total Air	
	Excess Air	58.54 -%
<b>FURNACE</b>		
	Furnace In Temp	869.86 degC
	High Temp Superheater	779.43 degC
	Low Temp Superheater	699.61 degC
	Economizer	418.21 degC
<b>PERFORMANCE</b>		
	NPHR	Kcal/kWh
	Thermal Efficiency	-%
	Boiler Efficiency	-%

SWITCH CALCULATION

BOILER COMBUSTION SYSTEM  
PLTU BENGKAYANG 2X50 MW



FLUE GAS

Volumetric Flow (db)

150852.16 Nm3/h

SO2

0.03 %-db

783.9 mg/Nm3

CO2

14.15 %-db

21339.35 Nm3/h

NO2

0.08 %-db

1726.79 mg/Nm3

Description

Kadar SO2 yang dihasilkan melebihi Standar Baku Mutu Emisi Pembangkit



EMMISSION



OPERATION  
FORECASTING

### COAL BLENDING TYPE

Single  Double  Triple

COAL ID-I	COAL ID-II	COAL ID-III	COAL BLEND
Coal Feed 31.09 T/h	Coal Feed T/h	Coal Feed T/h	Coal Feed T/h
Composition 100 -%	Composition -%	Composition -%	Composition -%
Ult-Analysis C 36.77 %-arb H 2.76 %-arb O 9.64 %-arb N 0.51 %-arb S 0.19 %-arb MC 41.48 %-arb ASH 8.65 %-arb	Ult-Analysis C %-arb H %-arb O %-arb N %-arb S %-arb MC %-arb ASH %-arb	Ult-Analysis C %-arb H %-arb O %-arb N %-arb S %-arb MC %-arb ASH %-arb	Ult-Analysis C %-arb H %-arb O %-arb N %-arb S %-arb MC %-arb ASH %-arb

GCV 3435.73 kcal/kg


**CALCULATE** **RESET**

### OPERATING CONDITION

<input checked="" type="radio"/> O2 Content in FG	O2 Content	7.89 %
<input type="radio"/> PA and SA	Primary Air	[REDACTED]
	Secondary Air	[REDACTED]
	Air Temp	179.34 degC
	Steam Flow	125 T/h
	Nett Generator Output	40.73 MWh
<b>AIR</b>	Total Air	157888.17 Nm3/h
	Excess Air	63.01 -%
<b>FURNACE</b>	Furnace In Temp	656.9 degC
	High Temp Superheater	420.3 degC
	Low Temp Superheater	391.65 degC
	Economizer	314.1 degC
<b>PERFORMANCE</b>	NPHR	2622.56 Kcal/kWh
	Thermal Efficiency	32.82 -%
	Boiler Efficiency	-%

**INACTIVE** (with red arrow pointing to Primary Air field)

## BOILER COMBUSTION SYSTEM PLTU BENGKAYANG 2X50 MW



### FLUE GAS

Volumetric Flow (db)	155180.85 Nm3/h
SO2	0.03 %-db
	762.03 mg/Nm3
CO2	13.75 %-db
	21339.35 Nm3/h
NO2	0.08 %-db
	1678.62 mg/Nm3

Description  
Kadar SO2 yang dihasilkan melebihi Standar Baku Mutu Emisi Pembangkit

# OPERATION FORECAST BY MODEL ML (ON PROGRESS)

CONVERSION

FLUE GAS

Volumetric Flow (db)

150852.16 Nm3/h

COAL ID-I COAL ID-II COAL ID-III

Coal Feed Coal Feed Coal Feed

31.09 T/h T/h T/h

Composition Composition Composition

100 %- %-% %-%

Ult-Analysis Ult-Analysis Ult-Analysis

C 36.77 %-arb c %-arb c %-arb

H 2.76 %-arb H %-arb H %-arb

O 9.64 %-arb O %-arb O %-arb

N 0.51 %-arb N %-arb N %-arb

S 0.19 %-arb S %-arb S %-arb

MC 41.48 %-arb MC %-arb MC %-arb

ASH 8.65 %-arb ASH %-arb ASH %-arb

OPERATION FORECAST

INPUT PARAMETER

COAL FEED

GROSS CALORIVIC VALUE COAL FEEDING FLOW

KCAL/KG TON/H

WATER FEED

WATER FEEDING TEMP WATER FEEDING FLOW

DEGC TON/H

OPERATION CONDITION

BED FURNACE TEMP TARGET OUTPUT

DEGC MW

AIR FLOW CONTROL

PRIMARY AIR


NM3/H

TOTAL SECONDARY AIR

NM3/H

PREDICT

RESET



EMMISSION



OPERATION FORECASTING



- TIM PELAKSANA
- Ketua Tim : Prof. Ir. Yazid Bindar, M.Sc, IPM, PhD
- Tenaga Ahli Utama:
  1. Dr. Ir. Abrar Riza, MT
  2. Dr.-Ing. Ir. Anton Irawan, MT, IPM, Asean Eng
  3. Teguh Kurniawan, ST.,MT, PhD
  4. Hafid Alwan, ST.,MT
- Engineer:
  1. Asep Kurniawan, ST
  2. Imam Mardhatillah Fajri ST. MT.,
  3. Anisa Helena Isma Putri, ST